

BOQ -NEW PET CT -MGPS						
SL	DESCRIPTION	UNIT	QTY	Rate	TOTAL	REMARKS
1	Copper piping					
	Supply, Installation, Testing and Commissioning of Colour coded Copper Piping As per EN13348-2016/ASTM B819 standards. with, solid drawn,seamless, dioxidised, non-arsenical, half hard,tempered, degreased copper pipes confirming to the standards. and with Copper fittings. All copper pipes should be degreased and delivered capped at both					Mex flow /JENYA
1.1	Copper pipe 12mm OD X 0.7 mm thick	Mtr	20			
1.2	Copper pipe 15mm OD X 0.9 mm thick	Mtr	115			
1.3	Copper pipe 22mm OD X 0.9 mm thick	Mtr	39			
1.4	Copper pipe 28mm OD X 0.9 mm thick	Mtr	RO			
1.5	Threaded GI rods, slotted rails and fasteners as per standard spacing and all other accessories required	No	20			
2	Medical Gas Terminal Outlet-					
	Supply, Installation, Testing and Commissioning ofPB Standard Outlet. The gas outlets shall be colour coded gas specific CE Certified Brand -AKTIV PB -A					AKTIV PB
2.1	O2	No	4			
2.2	N2O	No	1			
2.3	MA4	No	1			
2.4	Vacuum	No	4			
2.5	S.S Matching probes for outlets					
2.6	Outlet Beacon medaes 4 Digit type PB model	No				
3	Area Valve Box with Area Alarm Panel: Integrated alarm panel and AVSU with pipe top entry. Microprocessor based module. LED display for Normal, High & Low. PED: 2014/68/EU certified full port ball valve					AKTIV
3.1	4 Gas service	NOs	1			
	TOTAL (Basic)					
	GST @ 18%					
	G-TOTAL (Includung GST)+B24:I27					